



Complete Analytical Solution
ISO 14001 : 2015 & ISO 9001 : 2015 Certified

SHREE RAM TESTING LABORATORIES

ISO 14001 : 2015 & ISO 9001 : 2015 Approved Laboratory

Lab: A-2/103, Site-V, UPSIDC Industrial Area, Kasna, Greater Noida-201306

H.O. 223, 2nd Floor, Living Style Mall, Jasola, New Delhi-110025

Mob: 9953984801, 9717160780, 9999024801, E-mail: stl.noida@gmail.com

E-mail: info@shreeramlab.com, shreeramlab@yahoo.com, Website: www.shreeramlab.in

TEST REPORT

Issued to : M/S Grads International School HS-42, Eta-2, 130 Meter Road, Greater Noida (U.P)	Report No.	W-230921-01
	Report date:	25/09/2021
	Sample Received:	23/09/2021
	Analysis date:	23/09/2021 to 25/09/2021
	Sampled By:	Customer

Sample Description: R.O Water (Drinking Water)

P- 1/1

Condition of Sample: Received in Sealed & Marked Plastic Bottle.

RESULT

Drinking Water–Essential Tests as per IS 10500:2012

S.No.	Parameters (Units)	Test Method	Results	Requirement as per IS: 10500-2012
1.	Odour	IS:3025(P-5) 1983	Unobjectionable	Unobjectionable
2.	Taste	IS:3025(P-8) 1984	Agreeable	Agreeable
3.	Colour (Hazen)	IS:3025(P-4) 1983	< 1.0	5 max
4.	Turbidity (NTU)	IS:3025(P-10) 1984	Nil	1 max
5.	pH value (at 25°C)	IS:3025(P-11) 1983	6.90	6.5 to 8.5
6.	Total Dissolved solids (mg/l)	IS:3025(P-16) 1984	54	500 max
7.	Total Hardness (as CaCO ₃) (mg/l)	IS 3025 P-21:1983	16	200 max
8.	Chloride (as Cl) (mg/l)	IS:3025(P-32) 1988	15.31	250 max
9.	Iron (as Fe) (mg/l)	IS:3025(P-53) 1964	0.012	0.3 max
10.	Residual Free Chlorine(mg/l)	IS:3025(P-26) 1986	Nil	0.20 max
11.	Fluoride (as F) (mg/l)	APHA 4500 (D)	0.014	1.0 max
12.	MICROBIOLOGICAL PARAMETERS			
i	Coliform (per 100ml)	IS 1622:1996	Absent	0 max
ii	E. Coli (per 100ml)	IS 1622:1996	Absent	0 max

Remark: The Tested Parameters meet as per BIS specification.

END OF REPORT

TESTED BY

AUTHORIZED SIGNATORY



Note:- (1) The above results are related only to the test performed on the sample, Endorsement to product is neither inferred. (2) This report is not to be reproduced wholly or in part & can not be used as an evidence in the court of law & should not be used in a any advertising media without special permission in writing (3) Sample will be destroyed after 30 days from the date of reporting unless otherwise specified. (4) Total liability of our lab is limited to the invoice amount (5) report refers to the sample drawn by shree ram testing Laboratories unless mentioned otherwise



GREATER NOIDA INDUSTRIAL DEVELOPMENT AUTHORITY
Plot No.01, Sector Knowledge Park-IV, Greater Noida
Distt.- Gautam Budh Nagar (UP)


Ref.: H.D./2021/ 814

Date: 24/08/2021

SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by under signed from **Health Department, GNIDA** inspected the **Grads International School**, HS-42, Sector Eta-2, Greater Noida, Distt-G.B. Nagar (U.P.) premises has been found satisfactory during the inspection. You are requested to ensure the above conditions throughout the session as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of **One Year**.


Senior Manager (Health)

वरिष्ठ प्रबन्धक (स्वास्थ्य)
ग्रेड नोड औड नोड प्राधिकरण

To,

Admin Officer
Grand International School
HS-42, Sector Eta-2, Greater Noida
Distt-G.B. Nagar (U.P.)