



Complete Analytical Solution

SHREE RAM TESTING LABORATORIES

ISO 14001:2015 & ISO 9001:2015 Approved Laboratory
A-2/103 Site V, UPSIDC Industrial Area Kasna Greater Noida
HO-223 2nd Floor Living Style Mall Jasola New Delhi-25

Mob. 9953984801, 9717160780

E-mail: stl.noida@gmail.com

shreeramlab@yahoo.com

Tax Invoice

Date: 22/03/2025

No: 402

GSTIN: 09AGTPT1112F12A

PAN No: AGTPT1112F

SAC NO: 998346

Issued To: M/s Grads International School
F-3/14, Krishna Nagar, Krishna Nagar,
East Delhi, Delhi, 110051

GSTIN-: 07AAOAS8270R1ZD

State Code- 07

S.N	Parameters	Qty.	Rate (Rs.)	Price(Rs.)
01.	Testing of Drinking Water Essential Test as per IS:10500 (2012)	01	4,000/-	4,000/-
			Transportation Charge	nil /-
			Total	4,000/-
			SGST @9%	360/-
			CGST @9%	360/-
			IGST @18%	1/-
			Net Amount	4,720/-

Rs. Four Thousand Seven Hundred Twenty only.

Bank Detail-

NAME- SHREE RAM TESTING LABORATORIES

BANK- PUNJAB NATIONAL BANK

ADD- NRI CITY, SECTOR- OMEGA

GREATER NOIDA-G.B. NAGAR

A.C. No- 4603002100001456

IFS CODE- PUNB0460300

Shree Ram Testing Laboratories

A-2/103, Site-V UPSIDC

Shree Ram Testing Laboratories

Greater Noida-201306

Computer generated signature not required

U.P.



Complete Analytical Solution
ISO 14001 : 2015 & ISO 9001 : 2015 Certified

SHREE RAM TESTING LABORATORIES

ISO 14001 : 2015 & ISO 9001 : 2015 Approved Laboratory

Lab: A-2/103, Site-V, UPSIDC Industrial Area, Kasna, Greater Noida-201306
H.O. 223, 2nd Floor, Living Style Mall, Jasola, New Delhi-110025

Mob: 9953984801, 9717160780, 9999024801, E-mail: stl.noida@gmail.com
E-mail: shrooramlab@yahoo.com, info@shrooramlab.com Website: www.shrooramlab.in

TEST REPORT

Issued to : M/s Grads International School F-3/14, Krishna Nagar, Krishna Nagar, East Delhi, Delhi, 110051	Report No.	W-210325-01
	Report date:	21/03/2025
	Sample Received:	21/03/2025
	Analysis date:	21/03/2025 to 24/03/2025
	Sampled By:	customer

Sample Description: Drinking Water

Received Sample in Sealed and marked Plastic Bottle

RESULT

Drinking Water-Essential Tests as per IS 10500:2012

S.N.	Parameters (Units)	Test Method	Results	Requirement as per IS: 10500-2012
1.	Odour	IS:3025(P-5) 2018	Unobjectionable	Unobjectionable
2.	Taste	IS:3025(P-8) 1984 (RA- 2017)	Agreeable	Agreeable
3.	Colour (Hazen)	IS:3025(P-4) 2021	<1.0	5 max
4.	Turbidity (NTU)	IS:3025(P-10) 1984 (RA- 2017)	Nil	1 max
5.	pH value (at 25 °C)	IS:3025(P-11) 1983 (RA- 2017)	6.85	6.5 to 8.5
6.	Total Dissolved solids (mg/l)	IS:3025(P-16) 1984 (RA- 2017)	53	500 max
7.	Total Hardness (as CaCO ₃) (mg/l)	IS 3025 P-21:2009 (RA- 2019)	20	200 max
8.	Chloride (as Cl) (mg/l)	IS:3025(P-32) 1988 (RA- 2019)	16.14	250 max
9.	Iron (as Fe) (mg/l)	IS:3025(P-53) 2003 (RA- 2019)	0.01	0.3 max
10.	Residual Free Chlorine(mg/l)	IS:3025(P-26) 2021	0.012	0.20 max
11.	Fluoride (as F) (mg/l)	APHA 4500 (D)	0.010	1.0 max
12.	Total Alkalinity (as CaCO ₃), (mg/l)	IS:3025(P-23)- 1986 (RA- 2019)	105	200 max
13.	Magnesium (as Mg), (mg/l)	IS:3025(P-46)- 1994 (RA- 2019)	4.38	30 max
14.	Aluminum (as Al) (mg/l)	IS:3025(P-55)- 2003 (RA- 2019)	Not Detected	0.03 max
15.	Zinc (as Zn), (mg/l)	IS:3025(P-49)- 1994 (RA- 2019)	0.01	5 max
16.	Lead (as Pb), (mg/l)	IS:3025(P-47)- 1994 (RA- 2019)	Not Detected	0.01 max
17.	Mercury (as Hg), (mg/l)	IS:3025(P-48)- 1994 (RA- 2019)	Not Detected	0.001 max
18.	Total Arsenic (as As), (mg/l)	IS:3025(P-37)- 1988 (RA- 2019)	Not Detected	0.01 max
19.	MICROBIOLOGICAL PARAMETERS			
i	Coliform (cfu/100ml)	IS 1622:1981 (RA- 2019)	Absent	0 max
ii	E. Coli (cfu/100ml)	IS 1622:1981 (RA-2019)	Absent	0 max

Remark: The Tested Parameters meet as per BIS specification.

END OF REPORT

TESTED BY

AUTHORISED



Note:- (1) The above results are related only to the test performed on the sample, Endorsement to product is neither inferred. (2) This report is not to be reproduced wholly or in part & can not be used as an evidence in the court of law & should not be used in a any advertising media without special permission in writing (3) Sample will be destroyed after 30 days from the date of reporting unless otherwise specified.

(4) Total liability of our lab is limited to the invoice amount (5) report refers to the sample drawn by shree ram testing Laboratories unless mentioned otherwise